

Certificate of Approval

VALVE FIRE TEST

PREPARED FOR:

VALUE VALVES CO., LTD.

**No. 9, Chun Shan Rd., Tu-Cheng Industrial District., Taipei
Hsien, Taiwan, 236, R.O.C.**

PER ANSI/API STANDARD 607, FIFTH EDITION, JUNE 2005

ISO 10497-5:2004(Identical)

SIZE/RATING/BODY MATERIALS:

4"/CLASS 150/ASTM A351

BUTTERFLY VALVE

VALVE DRAWING NO.: T920000-G01

MIRDC NO: 9507031

TEST DATE: July. 28, 2006

TEST RESULTS: PASS

Johnson Hu

LABORATORY CHIEF

Wayne Liu

DIRECTOR

DATE :Aug. 07 2006

**METAL INDUSTRIES RESEARCH & DEVELOPMENT CENTRE
REGIONAL R&D SERVICE DEPARTMENT**

6F,No162-24, SEC.3,Hsin-Yi ROAD ,Taipei 106, Taiwan, R.O.C

Tel:886-2-27013181 Fax:886-2-27085460,27066785